

additional papers 1



Licensing Sub-Committee

Tue 8 Jun
2021
2.00 pm

Virtual meeting

REDDITCH BOROUGH COUNCIL



www.redditchbc.gov.uk

**If you have any queries on this Agenda please contact
Pauline Ross**

**Town Hall, Walter Stranz Square, Redditch, B98 8AH
Tel: (01527) 881406**

e.mail: p.ross@bromsgroveandredditch.gov.uk



Licensing Sub-Committee

Tuesday, 8th June, 2021

2.00 pm

Microsoft Teams

-
6. Premises Licence Application: Chillies (former Blue Inn) Far Moor Lane Winyates Redditch B98 0SD (Pages 1 - 4) – **Additional papers presented at the Hearing.**

This page is intentionally left blank

Headquarters
Hindlip Park
Worcester
WR3 8SP

Tel 0345 122 4454
Fax 01905 357 466
Web www.hwfire.org.uk
Email info@hwfire.org.uk

Bromsgrove Police & Fire Centre, Slideslow Drive, Bromsgrove, B60 1GN



HEREFORD & WORCESTER

HWFR
FIRE AND RESCUE SERVICE

RR003

Chief Fire Officer / Chief Executive
Jonathon Pryce MBA, Dip. GFireE

Mr Ansar Mahmood
Chillies Restaurant & Takeaway
Far Moor Lane
Winyates Green
Redditch
B98 0SD

Your reference

My reference N2702088/198734/CW/AM

Please ask for Chris Wainwright

Telephone 01527 572080

Email cwainwright@hwfire.org.uk

Date 27 April 2021

Dear Sir

**The Regulatory Reform (Fire Safety) Order 2005
ACTIONS TO ADDRESS FIRE SAFETY MATTERS**

Chillies Restaurant and Takeaway, Former Blue Inn Hotel, Far Moor Lane, Winyates Green, Redditch B98 0SD

Following the recent fire safety audit carried out at your premises on 27 April 2021, I am pleased to advise you that the standard of fire safety was reasonable. However, I am of the opinion that you can further improve the fire safety in your premises to a satisfactory standard. The attached schedule sets out suggested improvements.

My audits of premises are based on sampling inspection of your fire safety arrangements and may not have identified every deficiency. You remain responsible for reviewing your fire risk assessment, considering the adequacy of your existing arrangements and any extra measures that are needed to safeguard people.

I would be grateful if you could spend a few minutes completing our Client Feedback Form, which will allow the Fire and Rescue Service to improve its performance and service to businesses. This is available on our website at www.hwfire.org.uk. Click on 'Safety and Advice', 'Business Fire Safety' and then 'Rate your visit' or, if receiving this letter via email, click on the following link <http://www.hwfire.org.uk/safety-and-advice/business-safety/rate-your-visit/>. Thank you for your time and assistance.

If you want to ask questions about this letter and schedule, or require any fire safety advice in the future, please do not hesitate to contact me.

Yours faithfully



Authorised Fire Safety Inspecting Officer
on behalf of Hereford & Worcester Fire Authority

Enc: Schedule of Works

Responding in the time of need
Protecting from fire and other risks
Preventing harm and promoting well being

File Ref: N2702088.

HEREFORD & WORCESTER FIRE AND RESCUE SERVICE

Premises: Chillies Restaurant and Takeaway

Fire Safety Officer: Chris Walnwright

Date of Audit: 27 April 2021

SCHEDULE**Note to this schedule:-**

- **The Government guidance most suitable to your premises is Fire Safety Risk Assessment :-**
 - **Sleeping Accommodation - ISBN 13: 978 1 85112 817 4.**
 - **Small & Medium Places of Assembly - ISBN 13: 978 1 85112 820 4.**
- **Before you make certain changes to your premises you may have to apply for approval from statutory bodies and/or others having interest in them.**
- **If you have any doubt about the need for approval you should ask the relevant body, for example, you may have to apply for approval from Building Control to make material alterations. You might also need the property owners permission.**

1. Fire Safety Matters under Article 9 – failure to carry out a fire risk assessment

There was no evidence that a suitable and sufficient fire risk assessment has been carried out.

Required Action that will identify the safety measures you have in place and any further measures you might need to take

You must carry out a fire risk assessment. Guidance on this is available in the HM Government Guide "Fire Safety Risk Assessment - Small & Medium Places of Assembly - ISBN 13: 978 1 85112 820 4". You can download this guide free from www.hwfire.org.uk (click on "Business Fire Safety" and then 'Fire Risk Assessment Guides').

Your fire risk assessment must also address the deficiencies we identified during our audit which are detailed in this schedule.

You must then make a record of the significant findings which will include:-

- A record of the preventive or protective measures which are already in place to control the risk from fire; it may be helpful to record some of this information on a scale plan of the premises.
- Any further action you identify as necessary and a reasonable timescale for its completion.
- People or groups identified by the assessment as being especially at risk.

Your risk assessment is to be reviewed frequently in order to keep it up to date and particularly if:-

- there is a reason to suspect that it is no longer valid; or
- there has been a significant change in the matters to which it relates including when the premises, work processes, or organisation of the work undergoes significant changes, extensions, or conversions.

The responsible person must take action or make changes identified as necessary from the fire risk assessment.

2. Fire Safety Matters under Article 8 – Inadequate measures to reduce the risk of fire spread

Your measures to reduce risk from the spread of fire are not adequate; in particular:-

- Penetrations by pipes or cables within the boiler room are not effectively fire stopped.

Required action to reduce the risk of the spread of fire

- Install fire-stopping around pipes and services where they pass through ceiling and walls.

3. Fire Safety Matters under Article 14 – escape routes and exits

People are unable to evacuate the premises as quickly and as safely as possible:-

- Fire exits and doors on escape routes could not be easily and immediately opened from the inside in an emergency. **Fire exit in kitchen locked with key.**
- There are inadequate arrangements for evacuating people with disabilities.

Required action to ensure that escape routes (corridors, stairs and doors) can be safely used whenever they are needed

- Final exit doors should be quickly and easily openable without a key or code in the event of a fire. **Push pads or Lever handles would be acceptable due to staff exit only.**
- Provisions for the safe evacuation of disabled people should be reviewed and necessary improvements implemented. Guidance is available in the HM Government supplementary guide **Fire Safety Risk Assessment – Means of Escape for Disabled People** and you can download this guide free from www.hwfire.org.uk (click on "Business fire safety" and then 'Fire Risk Assessment Guides').
- Your fire safety management arrangements should be reviewed to ensure that all exit routes, exit doors and other escape provisions are regularly monitored.